

MECHANICAL ADDENDUM M-1

PROJECT:	Rossland Arena Safety Improvements	DATE:	Jun. 22, 2018
CLIENT:	Fairbank Architects Ltd.	JOB NO.:	18070

The following revisions supersede the information contained in the original drawings and specifications issued for the above project, to the extent referenced, and shall become part thereof. No considerations will be allowed for extras due to the Contractor or any Subcontractor or Supplier not being familiar with this Addendum.

- 1.) The voltage and phase of unit heater (UH-1) to be updated to 600V, 3 phase.

UNIT HEATER SCHEDULE

	UH-1
MAKE	REZNOR
MODEL	EXUB
LOCATION	MECH ROOM
GAS INPUT	25 KW
BLOWER CFM	2100 CFM
DIMENSIONS (HxWxL)	27"x34"x23.25"
WEIGHT	261 lb
ELECTRICAL	600/3/60
NOTES	1, 2

1. EXPLOSION RESISTANT UNIT HEATER
2. C/W EXPLOSION RESISTANT THERMOSTAT
3. UNIT HEATER SUPPLIED BY DIV. 15, INSTALLED BY DIV. 16

- 2.) The emergency shower, ES-1, and the associated DCW, DHW and sanitary drain piping shown on mechanical drawing M1.01 and the equipment schedule on drawing M2.02 to be removed from the tender documents.
- 3.) The Mechanical contractor to ensure that a tender amount is included for increasing the size of the opening in the exterior wall for the new intake louvre, L1, and motorized damper. The new louvre size is 36"x24" shown on mechanical drawing M2.01.

End of Addendum M-1